



Product certificate K46428/04

Issued 2017-01-01

Replaces K46428/03

Page 1 of 3

SANPRESS tube 1.4521 and 1.4401 Seamless and welded stainless steel tubes for drinking water installations

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Viega Technology GmbH & Co. KG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K762/03 "Seamless and welded stainless steel tubes for drinking water installations" dated 01-02-2012.



Luc Leroy
Kiwa

Publication of the certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Supplier
Viega Technology GmbH & Co. KG
Viega Platz 1
57439 ATTENDORN
Germany
Tel. +49 (0)2722 61-0
Fax +49 (0)2722 61-1415
info@viega.de
www.viega.de

SANPRESS tube 1.4521 and 1.4401 Seamless and welded stainless steel tubes for drinking water installations

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate.

SANPRESS inox tubes 1.4521

SANPRESS inox tubes in the following diameters (mm):
15, 18, 22, 28, 35, 42, 54 mm

SANPRESS inox XL tubes in the following diameters (mm):
64.0, 76.1, 88.9 and 108 mm

SANPRESS inox tubes 1.4401

SANPRESS inox tubes in the following diameters (mm):
15, 18, 22, 28, 35, 42, 54 mm

SANPRESS inox XL tubes in the following diameters (mm):
64.0, 76.1, 88.9 and 108 mm

SANPRESS tube 1.4521 and 1.4401 Seamless and welded stainless steel tubes for drinking water installations

FITNESS FOR CONTACT WITH DRINKING WATER

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in, for confidentiality reasons, the undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa[®]-mark products are marked with the wordmark "KIWA together with  or the abbreviated word mark .

Place of the mark:

- on the tube, with a maximum distance of 500 mm between the marks.

Compulsory specifications:

- manufacturer's name or logo;
- production date or code;
- outer diameter;
- material designation.

Method of marking:

- non-erasable;
- visible after assembly

APPLICATION AND USE

The products are to be applied in combination with fittings meeting the requirements of BRL-K774 in drinking water installations in which a maximum working pressure of 1.0 MPa and a maximum temperature of 90 °C is permitted.

Remark: Because of risk of corrosion, it is not permitted to weld, solder or braze these pipes, as well as hot forge or bend them, unless additional requirements and specific treatment methods are formulated.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Viega Technology GmbH & Co. KG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.